

CALISTOGA FIRE DEPARTMENT

MEMORANDUM

TO: Erik Lundquist/ Sr.Planner

FROM: Steve Campbell / Fire Chief

SUBJECT: Conceptual Design Review for 331 Silverado Trail- Brain Arden Wines

DATE: 6/13/2011

The Fire Department has completed its conceptual review of the submittal materials received May 31, 2011 regarding the above referenced application.

1. All road width shall be a minimum of 20feet and 26feet at hydrant locations.
2. Fire flow studies should be conducted as early as possible to determine needed fire flow and pressure requirements, there is the possibility this project will need a fire pump.
3. All building will have Fire Sprinklers.
4. The project will be in a wildland hazard area, given the location of Mt Washington.