

## City of Calistoga Monthly Summary of the Kimball Reservoir Bypass - May, 2015

Month	Day	Water Surface Elevation (ft)	5-day Average Inflow (cfs)	Bypass Target Flow (cfs)	70% of Bypass Target Flow (cfs)	Bypass Actual Flow (cfs)	3-day Average Bypass Actual Flow (cfs)	3-day Average Bypass Target Flow (cfs)	Reservoir Spilling (yes/no)
4	30	574.14	0.19	0.14	0.10	0.17	0.16	0.15	No
5	1	574.04	0.17	0.11	0.08	0.16	0.16	0.13	No
5	2	574.00	0.15	0.10	0.07	0.14	0.16	0.12	No
5	3	573.98	0.15	0.09	0.06	0.14	0.15	0.10	No
5	4	573.97	0.13	0.09	0.06	0.08	0.12	0.09	No
5	5	573.89	0.11	0.08	0.06	0.12	0.11	0.09	No
5	6	573.79	0.11	0.07	0.05	0.10	0.10	0.08	No
5	7	573.71	0.12	0.07	0.05	0.10	0.10	0.07	No
5	8	573.62	0.14	0.07	0.05	0.10	0.10	0.07	No
5	9	573.58	0.12	0.08	0.06	0.10	0.10	0.07	No
5	10	573.55	0.09	0.07	0.05	0.12	0.10	0.07	No
5	11	573.49	0.12	0.05	0.04	0.07	0.10	0.07	No
5	12	573.38	0.08	0.07	0.05	0.10	0.10	0.06	No
5	13	573.28	0.06	0.05	0.04	0.09	0.09	0.06	No
5	14	573.19	0.10	0.04	0.03	0.10	0.10	0.05	No
5	15	573.17	0.11	0.06	0.04	0.06	0.08	0.05	No
5	16	573.15	0.07	0.07	0.05	0.07	0.08	0.06	No
5	17	573.14	0.09	0.04	0.03	0.06	0.06	0.06	No
5	18	573.13	0.09	0.05	0.04	0.06	0.06	0.05	No
5	19	573.05	0.07	0.05	0.04	0.06	0.06	0.05	No
5	20	572.97	0.08	0.04	0.03	0.06	0.06	0.05	No
5	21	572.87	0.08	0.05	0.04	0.06	0.06	0.05	No
5	22	572.79	0.13	0.05	0.04	0.06	0.06	0.05	No
5	23	572.75	0.11	0.08	0.06	0.06	0.06	0.06	No
5	24	572.74	0.11	0.07	0.05	0.06	0.06	0.07	No
5	25	572.67	0.11	0.07	0.05	0.06	0.06	0.07	No
5	26	572.57	0.11	0.07	0.05	0.06	0.06	0.07	No
5	27	572.47	0.06	0.07	0.05	0.10	0.07	0.07	No
5	28	572.37	0.08	0.04	0.03	0.11	0.09	0.06	No
5	29	572.28	0.09	0.05	0.04	0.10	0.10	0.05	No
5	30	572.23	0.07	0.05	0.04	0.08	0.10	0.05	No
5	31	572.22	0.08	0.04	0.03	0.05	0.08	0.05	No

**Total Monthly Target:** 1,286,081 gallons

**Total Monthly Actual:** 1,730,300 gallons