

City of Calistoga Monthly Summary of the Kimball Reservoir Bypass - August, 2015

Month	Day	Water Surface Elevation (ft)	5-day Average Inflow (cfs)	Bypass Target Flow (cfs)	70% of Bypass Target Flow (cfs)	Bypass Actual Flow (cfs)	3-day Average Bypass Actual Flow (cfs)	3-day Average Bypass Target Flow (cfs)	Reservoir Spilling (yes/no)
7	31	567.12	0.02	0.02	0.01	0.03	0.02	0.01	No
8	1	567.09	0.01	0.02	0.01	0.03	0.03	0.02	No
8	2	567.07	0.02	0.01	0.01	0.02	0.02	0.02	No
8	3	567.06	0.02	0.02	0.01	0.02	0.02	0.02	No
8	4	566.92	0.02	0.02	0.01	0.03	0.02	0.02	No
8	5	566.83	0.04	0.02	0.01	0.02	0.02	0.02	No
8	6	566.71	0.06	0.04	0.03	0.03	0.02	0.03	No
8	7	566.58	0.08	0.06	0.04	0.03	0.02	0.04	No
8	8	566.51	0.07	0.08	0.06	0.11	0.05	0.06	No
8	9	566.49	0.09	0.07	0.05	0.11	0.08	0.07	No
8	10	566.45	0.07	0.09	0.06	0.07	0.10	0.08	No
8	11	566.28	0.05	0.07	0.05	0.17	0.12	0.08	No
8	12	566.15	0.03	0.05	0.04	0.09	0.11	0.07	No
8	13	566.02	0.05	0.03	0.02	0.11	0.12	0.05	No
8	14	565.88	0.04	0.05	0.04	0.11	0.11	0.04	No
8	15	565.82	0.04	0.04	0.03	0.11	0.11	0.04	No
8	16	565.78	0.05	0.04	0.03	0.12	0.12	0.04	No
8	17	565.75	0.04	0.05	0.04	0.06	0.10	0.04	No
8	18	565.59	0.03	0.04	0.03	0.08	0.09	0.04	No
8	19	565.50	0.03	0.03	0.02	0.06	0.07	0.04	No
8	20	565.37	0.03	0.03	0.02	0.07	0.07	0.03	No
8	21	565.24	0.04	0.03	0.02	0.07	0.06	0.03	No
8	22	565.20	0.03	0.04	0.03	0.07	0.07	0.03	No
8	23	565.18	0.04	0.03	0.02	0.07	0.07	0.03	No
8	24	565.15	0.01	0.04	0.03	0.06	0.06	0.04	No
8	25	565.02	0.01	0.01	0.01	0.07	0.06	0.03	No
8	26	564.89	0.02	0.01	0.01	0.06	0.06	0.02	No
8	27	564.77	0.02	0.02	0.01	0.04	0.06	0.01	No
8	28	564.65	0.03	0.02	0.01	0.03	0.04	0.02	No
8	29	564.62	0.03	0.03	0.02	0.03	0.03	0.02	No
8	30	564.60	0.03	0.03	0.02	0.02	0.03	0.03	No
8	31	564.58	0.02	0.03	0.02	0.02	0.02	0.03	No
Total Monthly Target:				743,213 gallons					
Total Monthly Actual:				1,263,900 gallons					