

**City of Calistoga Monthly Summary of the Kimball Reservoir Bypass - June, 2016**

Month	Day	Water Surface Elevation (ft)	5-day Average Inflow (cfs)	70% of Bypass Target Flow (cfs)		Bypass Actual Flow (cfs)	3-day Average Bypass Actual Flow (cfs)	3-day Average Bypass Target Flow (cfs)	Reservoir Spilling (yes/no)
				Bypass Target Flow (cfs)	Bypass Target Flow (cfs)				
5	31	578.37	0.31	0.19	0.13	0.20	0.20	0.20	No
6	1	578.29	0.28	0.19	0.13	0.24	0.21	0.19	No
6	2	578.21	0.26	0.17	0.12	0.20	0.21	0.18	No
6	3	578.13	0.28	0.16	0.11	0.21	0.22	0.17	No
6	4	578.04	0.25	0.17	0.12	0.21	0.21	0.17	No
6	5	577.95	0.23	0.15	0.11	0.21	0.21	0.16	No
6	6	577.88	0.30	0.14	0.10	0.59	0.34	0.15	No
6	7	577.81	0.29	0.18	0.13	0.15	0.32	0.16	No
6	8	577.74	0.26	0.17	0.12	0.15	0.30	0.16	No
6	9	577.65	0.26	0.16	0.11	0.19	0.16	0.17	No
6	10	577.55	0.25	0.16	0.11	0.22	0.19	0.16	No
6	11	577.46	0.17	0.15	0.11	0.18	0.20	0.16	No
6	12	577.37	0.15	0.10	0.07	0.16	0.19	0.14	No
6	13	577.27	0.14	0.09	0.06	0.16	0.16	0.11	No
6	14	577.18	0.14	0.08	0.06	0.15	0.16	0.09	No
6	15	577.09	0.14	0.08	0.06	0.15	0.15	0.08	No
6	16	577.01	0.10	0.08	0.06	0.08	0.13	0.08	No
6	17	576.94	0.11	0.06	0.04	0.09	0.11	0.07	No
6	18	576.86	0.11	0.07	0.05	0.07	0.08	0.07	No
6	19	576.79	0.11	0.07	0.05	0.06	0.07	0.07	No
6	20	576.71	0.12	0.07	0.05	0.07	0.07	0.07	No
6	21	576.62	0.14	0.07	0.05	0.10	0.08	0.07	No
6	22	576.53	0.11	0.08	0.06	0.09	0.09	0.07	No
6	23	576.44	0.12	0.07	0.05	0.10	0.10	0.07	No
6	24	576.36	0.11	0.07	0.05	0.10	0.10	0.07	No
6	25	576.25	0.09	0.07	0.05	0.09	0.10	0.07	No
6	26	576.17	0.09	0.05	0.04	0.08	0.09	0.06	No
6	27	576.07	0.08	0.05	0.04	0.08	0.08	0.06	No
6	28	575.97	0.06	0.05	0.04	0.08	0.08	0.05	No
6	29	575.87	0.03	0.04	0.03	0.08	0.08	0.05	No
6	30	575.79	0.05	0.02	0.01	0.07	0.08	0.04	No

**Total Monthly Target:** 1,984,055 gallons

**Total Monthly Actual:** 2,859,400 gallons