

## City of Calistoga Monthly Summary of the Kimball Reservoir Bypass - March, 2020

Month	Day	Water Surface Elevation (ft)	5-day Average Inflow (cfs)	Bypass Target Flow (cfs)	70% of Bypass Target Flow (cfs)	Bypass Actual Flow (cfs)	3-day Average Bypass Actual Flow (cfs)	3-day Average Bypass Target Flow (cfs)	Reservoir Spilling (yes/no)
2	29	576.38	0.71	0.41	0.29	0.53	0.56	0.44	No
3	1	576.34	0.69	0.43	0.30	0.46	0.52	0.42	No
3	2	576.30	0.66	0.41	0.29	0.43	0.47	0.42	No
3	3	576.16	0.54	0.40	0.28	0.46	0.45	0.41	No
3	4	576.13	0.65	0.32	0.22	0.48	0.45	0.38	No
3	5	576.07	0.50	0.39	0.27	0.45	0.46	0.37	No
3	6	576.01	0.48	0.30	0.21	0.47	0.47	0.34	No
3	7	575.96	0.48	0.29	0.20	0.45	0.46	0.33	No
3	8	575.89	0.56	0.29	0.20	0.41	0.44	0.29	No
3	9	575.85	0.43	0.34	0.24	0.37	0.41	0.31	No
3	10	575.79	0.52	0.26	0.18	0.42	0.40	0.30	No
3	11	575.73	0.50	0.31	0.22	0.40	0.40	0.30	No
3	12	575.67	0.48	0.30	0.21	0.40	0.41	0.29	No
3	13	575.61	0.47	0.29	0.20	0.35	0.38	0.30	No
3	14	575.57	0.50	0.28	0.20	0.40	0.38	0.29	No
3	15	575.55	0.52	0.30	0.21	0.32	0.36	0.29	No
3	16	575.51	0.53	0.31	0.22	0.31	0.34	0.30	No
3	17	575.45	0.53	0.32	0.22	0.36	0.33	0.31	No
3	18	575.41	0.56	0.32	0.22	0.32	0.33	0.32	No
3	19	575.37	0.53	0.34	0.24	0.33	0.34	0.33	No
3	20	575.30	0.48	0.32	0.22	0.37	0.34	0.33	No
3	21	575.25	0.50	0.29	0.20	0.37	0.36	0.32	No
3	22	575.18	0.48	0.30	0.21	0.35	0.36	0.30	No
3	23	575.12	0.46	0.29	0.20	0.32	0.35	0.29	No
3	24	575.07	0.44	0.28	0.20	0.34	0.34	0.29	No
3	25	575.03	0.48	0.26	0.18	0.35	0.34	0.28	No
3	26	574.97	0.46	0.29	0.20	0.36	0.35	0.28	No
3	27	574.92	0.48	0.28	0.20	0.34	0.35	0.28	No
3	28	574.85	0.49	0.29	0.20	0.37	0.36	0.29	No
3	29	574.81	0.51	0.29	0.20	0.36	0.36	0.29	No
3	30	574.76	0.48	0.31	0.22	0.32	0.35	0.30	No
3	31	574.70	0.48	0.29	0.20	0.35	0.34	0.30	No
<b>Total Monthly Target:</b>				6,262,376 gallons					
<b>Total Monthly Actual:</b>				7,616,000 gallons					