

## City of Calistoga Monthly Summary of the Kimball Reservoir Bypass - April, 2020

Month	Day	Water Surface Elevation (ft)	5-day Average Inflow (cfs)	Bypass Target Flow (cfs)	70% of Bypass Target Flow (cfs)	Bypass Actual Flow (cfs)	3-day Average Bypass Actual Flow (cfs)	3-day Average Bypass Target Flow (cfs)	Reservoir Spilling (yes/no)
3	31	574.70	0.48	0.29	0.20	0.35	0.34	0.30	No
4	1	574.63	0.46	0.29	0.20	0.33	0.33	0.30	No
4	2	574.56	0.47	0.28	0.20	0.36	0.35	0.29	No
4	3	574.49	0.41	0.28	0.20	0.31	0.33	0.28	No
4	4	574.41	0.39	0.25	0.18	0.35	0.34	0.27	No
4	5	574.48	0.54	0.23	0.16	0.32	0.32	0.25	No
4	6	574.56	0.73	0.32	0.22	0.34	0.33	0.27	No
4	7	574.60	0.85	0.44	0.31	0.35	0.33	0.33	No
4	8	574.56	0.93	0.51	0.36	0.46	0.38	0.42	No
4	9	574.50	1.00	0.56	0.39	0.63	0.48	0.50	No
4	10	574.40	0.91	0.60	0.42	0.87	0.65	0.56	No
4	11	574.28	0.77	0.55	0.39	0.84	0.78	0.57	No
4	12	574.20	0.69	0.46	0.32	0.67	0.79	0.54	No
4	13	574.14	0.68	0.41	0.29	0.53	0.68	0.47	No
4	14	574.06	0.65	0.41	0.29	0.52	0.57	0.43	No
4	15	573.96	0.56	0.39	0.27	0.43	0.49	0.40	No
4	16	573.90	0.54	0.34	0.24	0.42	0.46	0.38	No
4	17	573.82	0.48	0.32	0.22	0.39	0.41	0.35	No
4	18	573.74	0.43	0.29	0.20	0.39	0.40	0.32	No
4	19	573.67	0.39	0.26	0.18	0.30	0.36	0.29	No
4	20	573.58	0.38	0.23	0.16	0.30	0.33	0.26	No
4	21	573.49	0.32	0.23	0.16	0.28	0.29	0.24	No
4	22	573.41	0.28	0.19	0.13	0.23	0.27	0.22	No
4	23	573.33	0.25	0.17	0.12	0.22	0.24	0.20	No
4	24	573.24	0.21	0.15	0.11	0.19	0.21	0.17	No
4	25	573.15	0.20	0.13	0.09	0.18	0.20	0.15	No
4	26	573.06	0.18	0.12	0.08	0.15	0.18	0.13	No
4	27	572.96	0.15	0.11	0.08	0.15	0.16	0.12	No
4	28	572.87	0.14	0.09	0.06	0.17	0.16	0.11	No
4	29	572.78	0.13	0.08	0.06	0.15	0.15	0.09	No
4	30	572.72	0.15	0.08	0.06	0.11	0.14	0.08	No

**Total Monthly Target:** 5,667,805 gallons  
**Total Monthly Actual:** 7,061,700 gallons