

City of Calistoga Monthly Summary of the Kimball Reservoir Bypass - May, 2020

Month	Day	Water Surface Elevation (ft)	5-day Average Inflow (cfs)	Bypass Target Flow (cfs)	70% of Bypass Target Flow (cfs)	Bypass Actual Flow (cfs)	3-day Average Bypass Actual Flow (cfs)	3-day Average Bypass Target Flow (cfs)	Reservoir Spilling (yes/no)
4	30	572.72	0.15	0.08	0.06	0.11	0.14	0.08	No
5	1	572.65	0.16	0.09	0.06	0.10	0.12	0.08	No
5	2	572.59	0.18	0.10	0.07	0.10	0.10	0.09	No
5	3	572.52	0.18	0.11	0.08	0.12	0.11	0.10	No
5	4	572.43	0.20	0.11	0.08	0.14	0.12	0.11	No
5	5	572.36	0.19	0.12	0.08	0.12	0.13	0.11	No
5	6	572.27	0.19	0.11	0.08	0.16	0.14	0.11	No
5	7	572.17	0.17	0.11	0.08	0.14	0.14	0.11	No
5	8	572.10	0.18	0.10	0.07	0.14	0.14	0.11	No
5	9	572.01	0.18	0.11	0.08	0.15	0.14	0.11	No
5	10	571.93	0.17	0.11	0.08	0.14	0.14	0.11	No
5	11	571.83	0.15	0.10	0.07	0.14	0.14	0.11	No
5	12	571.84	0.26	0.09	0.06	0.12	0.13	0.10	No
5	13	571.78	0.26	0.16	0.11	0.12	0.13	0.12	No
5	14	571.73	0.28	0.16	0.11	0.18	0.14	0.14	No
5	15	571.65	0.29	0.17	0.12	0.21	0.17	0.16	No
5	16	571.55	0.31	0.17	0.12	0.21	0.20	0.17	No
5	17	571.51	0.26	0.19	0.13	0.22	0.21	0.18	No
5	18	571.48	0.29	0.16	0.11	0.19	0.21	0.17	No
5	19	571.46	0.34	0.17	0.12	0.21	0.21	0.17	No
5	20	571.47	0.44	0.20	0.14	0.19	0.20	0.18	No
5	21	571.48	0.54	0.26	0.18	0.22	0.21	0.21	No
5	22	571.43	0.54	0.32	0.22	0.31	0.24	0.26	No
5	23	571.36	0.56	0.32	0.22	0.44	0.32	0.30	No
5	24	571.28	0.53	0.34	0.24	0.40	0.38	0.33	No
5	25	571.27	0.49	0.32	0.22	0.39	0.41	0.33	No
5	26	571.24	0.41	0.29	0.20	0.34	0.38	0.32	No
5	27	571.15	0.39	0.25	0.18	0.35	0.36	0.29	No
5	28	571.05	0.31	0.23	0.16	0.33	0.34	0.26	No
5	29	570.96	0.27	0.19	0.13	0.26	0.31	0.22	No
5	30	570.86	0.21	0.16	0.11	0.24	0.28	0.19	No
5	31	570.78	0.21	0.13	0.09	0.22	0.24	0.16	No
Total Monthly Target:				3,522,182 gallons					
Total Monthly Actual:				4,269,600 gallons					