

City of Calistoga Monthly Summary of the Kimball Reservoir Bypass - July, 2023

Month	Day	Water Surface Elevation (ft)	5-day Average Inflow (cfs)	Bypass Target Flow (cfs)	70% of Bypass Target Flow (cfs)	Bypass Actual Flow (cfs)	3-day Average Bypass Actual Flow (cfs)	3-day Average Bypass Target Flow (cfs)	Reservoir Spilling (yes/no)
6	30	578.33	0.21	0.12	0.08	0.143	0.14	0.13	No
7	1	578.25	0.17	0.13	0.09	0.147	0.15	0.13	No
7	2	578.20	0.16	0.17	0.12	0.126	0.14	0.14	No
7	3	578.13	0.15	0.16	0.11	0.164	0.15	0.15	No
7	4	578.04	0.13	0.15	0.11	0.193	0.16	0.16	No
7	5	577.95	0.10	0.13	0.09	0.153	0.17	0.15	No
7	6	577.87	0.08	0.10	0.07	0.154	0.17	0.13	No
7	7	577.79	0.08	0.08	0.06	0.118	0.14	0.10	No
7	8	577.72	0.07	0.08	0.06	0.082	0.12	0.09	No
7	9	577.64	0.06	0.07	0.05	0.082	0.09	0.08	No
7	10	577.57	0.09	0.06	0.04	0.084	0.08	0.07	No
7	11	577.49	0.09	0.09	0.06	0.087	0.08	0.07	No
7	12	577.40	0.07	0.09	0.06	0.080	0.08	0.08	No
7	13	577.34	0.09	0.07	0.05	0.082	0.08	0.08	No
7	14	577.30	0.10	0.09	0.06	0.086	0.08	0.08	No
7	15	577.24	0.08	0.10	0.07	0.096	0.09	0.09	No
7	16	577.17	0.08	0.08	0.06	0.147	0.11	0.09	No
7	17	577.09	0.08	0.08	0.06	0.119	0.12	0.09	No
7	18	577.02	0.05	0.08	0.06	0.091	0.12	0.08	No
7	19	576.94	0.04	0.05	0.04	0.092	0.10	0.07	No
7	20	576.88	0.03	0.04	0.03	0.054	0.08	0.06	No
7	21	576.81	0.02	0.03	0.02	0.051	0.07	0.04	No
7	22	576.74	0.02	0.02	0.01	0.030	0.05	0.03	No
7	23	576.66	0.01	0.02	0.01	0.026	0.04	0.02	No
7	24	576.60	0.02	0.01	0.01	0.023	0.03	0.02	No
7	25	576.53	0.01	0.02	0.01	0.021	0.02	0.02	No
7	26	576.49	0.01	0.01	0.01	0.020	0.02	0.01	No
7	27	576.43	0.01	0.01	0.01	0.020	0.02	0.01	No
7	28	576.36	0.01	0.01	0.01	0.020	0.02	0.01	No
7	29	576.29	0.00	0.01	0.01	0.020	0.02	0.01	No
7	30	576.22	0.00	0.00	0.00	0.020	0.02	0.01	No
7	31	576.15	0.00	0.00	0.00	0.02	0.02	0.00	No
		Total Monthly Target:	1,318,395 gallons						
		Total Monthly Actual:	1,619,345 gallons						